

# SURAT GAS PROJECT - GIRRAWHEEN FIELD COMPRESSOR STATION

## Operational Noise Assessment

### Prepared for:

Arrow Energy Pty Ltd  
Level 39, 111 Eagle St  
Brisbane QLD 4001

SLR Ref: 620.12448.01606-R03  
Version No: -v1.0  
July 2024



## PREPARED BY

SLR Consulting Australia Pty Ltd  
ABN 29 001 584 612  
Level 16, 175 Eagle Street  
Brisbane QLD 4000 Australia  
T: +61 7 3858 4800  
E: brisbane@slrconsulting.com www.slrconsulting.com

## BASIS OF REPORT

This report has been prepared by SLR Consulting Australia Pty Ltd (SLR) with all reasonable skill, care and diligence, and taking account of the timescale and resources allocated to it by agreement with Arrow Energy Pty Ltd (the Client). Information reported herein is based on the interpretation of data collected, which has been accepted in good faith as being accurate and valid.

This report is for the exclusive use of the Client. No warranties or guarantees are expressed or should be inferred by any third parties. This report may not be relied upon by other parties without written consent from SLR.

SLR disclaims any responsibility to the Client and others in respect of any matters outside the agreed scope of the work.

## DOCUMENT CONTROL

Reference	Date	Prepared	Checked	Authorised
620.12448.01606-R03-v1.0	9 July 2024	Logan Le Petit	Glyn Cowie	Glyn Cowie

---

## EXECUTIVE SUMMARY

SLR Consulting Australia Pty Ltd (SLR) has been engaged by Arrow Energy (Arrow) to undertake a noise assessment of the Girrawheen Field Compressor Station (FCS), which is located approximately 18 km north of Miles, Queensland.

The Girrawheen FCS will facilitate the compression of low-pressure coal seam gas (CSG) and deliver medium-pressurised gas downstream to the gas sales delivery point. The facility consists of the following main processes:

- Screw compressors (up to four) which compress low-pressure coal seam gas (CSG),
- CSG fired internal combustion power generation plant equipped with a battery energy storage system (BESS). This provides electrical power to the facility mainly used to power the compressors.
- Multi-point ground flare (MPGF, to manage distressed gas),
- Slug catcher (to remove water in gas line; and
- Cyclone separator (to remove solids/fines in gas line).

The Girrawheen FCS incorporates several noise abatement technologies to reduce noise emissions including:

- FCS Compressors:
  - Compressor enclosures with acoustic lining to minimise noise emissions.
- FCS Engines:
  - Engine enclosures to minimise noise emissions,
  - Acoustically treated louvres on air intakes, and
  - Exhaust silencers.
- Flare noise:
  - The use of a MPGF with a radiation fence has been selected over an elevated flare or sonic tip ground flare due to the reduced noise levels (when noise level output is compared) and therefore, minimizing the potential for flare noise impact.

This noise assessment assesses the residual noise impact after the noise abatement techniques have been applied to avoid the potential for noise impact.

The Girrawheen FCS has been assessed for the following operating scenarios:

- Scenario 1 – Normal Operation at maximum operating capacity
  - Four (4) Howden 510 screw compressors running at 2,000 RPM with coolers, and
  - Sixteen (16) operating CSG fired power station (internal combustion engines) and two (2) spare 1875 kVA Aggreko GE J420E units with BESS.
  - Two (2) Centrifugal pumps.
- Scenario 2 – Flaring
  - MPGF to occur under four (4) separate flare flow rates being 163 MMscfd, 87 MMscfd, 58 MMscfd and 29 MMscfd.

## EXECUTIVE SUMMARY

Scenario 1 is typical of 24 hours 7 days operation and is considered normal operation which is likely to be constant and potentially audible during any period of the day.

Scenario 2 assesses flaring which occurs when a compressor trips or downstream capacity is restricted such that the gas being delivered to the facility (Girrawheen FCS) exceeds the delivery capacity. In these situations, gas must be flared until the well field can be turned down or compression/delivery capacity is restored. Flaring of gas occurs on rare occasions and is minimised to as low as reasonably practical (ALARP) through Arrow’s advanced gas management (further information is outlined below). The occurrence of flaring events are not scheduled (ie not limited to daytime only). Flaring during scheduled events, such as annual maintenance activities can be scheduled to occur during the day and gas flow is minimised to reduce gas loss (maximum flare rates do not occur on a scheduled basis).

A range of flare flow rates has been assessed, representing typical ranges for flaring events that may be experienced at the facility. Arrow has provided the following additional information regarding the facilities flaring flows rates:

- For approximately 88% of the time over an hourly period, no flaring is expected to occur (ie no flare noise from the facility).
- 95% of flaring events are predicted to be less than 29 MMscfd (or 9.5% of the time during an hourly period).
- Flaring events greater than 29 MMscfd are expected to occur approximately 2% of the time over an hourly period (<1% at night-time).

Flare flow rates between 58 MMscfd and 163 MMscfd have been used to assess the worst-case noise potential during the rare occurrence of maximum flare flow rate that may be experienced at the Girrawheen FCS. The assessment has considered the potential for a worst-case scenario where flaring occurs for a minimum 15-minute duration during any assessable period (day, evening and night). This is considered a conservative approach and should be considered along with the expected frequency of each flaring event.

The Girrawheen FCS operational noise assessment identified the following:

- The proposed Girrawheen FCS development is expected to meet all nominated noise criteria outlined in **Section 3.3** for both assessed weather conditions when operating under ‘normal operations’ (Scenario 1) and the maximum sound power noise level of 103 dBA is achieved for the Power Generation Units. The frequency octave band noise levels associated with the Power Generation Units and Screw Compressor Units are not to exceed those outlined in **Table 1**.

**Table 1 Maximum Octave Band Noise Levels**

Plant Items	Sound Power Level, LAeq dBA									Overall SWL dBA
	Octave Band Centre Frequency (Hz)									
	31.5	63	125	250	500	1k	2k	4k	8k	
Power Generator Unit, including Generator Engine Exhaust (Mitigated)	75	86	102	93	88	89	81	78	70	<b>103</b>

## EXECUTIVE SUMMARY

Plant Items	Sound Power Level, LAeq dBA									Overall SWL dBA
	Octave Band Centre Frequency (Hz)									
	31.5	63	125	250	500	1k	2k	4k	8k	
Mitigated Howden Screw Compressor Unit (fitted with acoustic panels)	71	76	84	101	99	95	92	87	78	<b>104</b>
Screw Compressor Coolers	73	87	96	100	101	101	95	91	83	<b>107</b>

- Predicted noise levels considering flaring noise from the MFGF in conjunction with other operating plant found the following:
  - Compliance at all receptors was achieved for all flare flow rates under neutral weather conditions.
  - Compliance at all receptors was achieved for all flare rates up to 58 MMscfd and under for all weather conditions. This represents 95% of expected flaring events that would potentially occur at the Girrawheen FCS.
  - At a flare flow rate of 87 MMscfd and above, marginal exceedance of the night-time noise limit of 28 dBA during adverse weather may occur at up to five (5) receptors. Noting, the worst case being up to two receptors too potentially exceed at the same time, GFCS-2 and GFCS-4 due to similar locality. All other receptors would be isolated occurrences.

The noise assessment included a minimum 'flat' overall 8.7 dB noise reduction to account for potential noise insertion loss from the 16.7 m radiation fence. Any change to the derived 8.7 dB noise reduction from the fence would see the predicted noise levels increase at the receptor for the flaring scenario (2) by an equal amount (1 dB reduction to the fences acoustic performance would equal a 1 dB increase to noise level predictions). It is also possible that the noise reduction due to the flare radiation fence is under-predicted in this assessment. If the noise reduction in the flare fence is greater than 8.7 dB, lower noise levels at the sensitive receptors would be expected for each flaring event.

---

<b>1</b>	<b>INTRODUCTION .....</b>	<b>9</b>
1.1	Background .....	9
1.2	Objectives of this Assessment .....	9
<b>2</b>	<b>SITE DESCRIPTION .....</b>	<b>11</b>
2.1	Site Location.....	11
2.2	Sensitive Receptors.....	11
2.3	Existing Noise Environment .....	12
2.4	Background Noise Levels .....	12
<b>3</b>	<b>REGULATORY FRAMEWORK.....</b>	<b>14</b>
3.1	Queensland Noise Regulations .....	14
3.2	DESI Guideline - Prescribing Noise Conditions for Petroleum and Gas Activities .....	15
3.2.1	Deemed Background Noise Levels .....	15
3.2.2	Noise Limits .....	15
3.2.3	Low Frequency Noise .....	16
3.3	Summary of Project Noise Conditions .....	16
<b>4</b>	<b>GIRRAWHEEN FCS OPERATIONAL NOISE ASSESSMENT .....</b>	<b>17</b>
4.1	Assessed Operational Scenarios .....	17
4.2	Noise Modelling .....	18
4.2.1	Noise Modelling Methodology .....	18
4.2.2	Noise Model Inputs .....	19
4.2.3	Calculation Method – CONCAWE .....	19
4.3	Assessed Meteorological Conditions .....	19
4.4	Modelled Plant Sound Power Levels .....	20
4.4.1	Multi-point Ground Flare Radiation Fence .....	21
4.5	Noise Assessment Results.....	22
4.5.1	Scenario 1 – Normal Operations .....	22
4.5.1.1	Scenario 1 – Normal Operations Noise Mitigation Recommendation.....	23
4.5.2	Scenario 2 – Flaring .....	25
4.6	Flare Noise Summary .....	26
4.7	Low Frequency Noise Assessment.....	27
<b>5</b>	<b>CONCLUSION.....</b>	<b>27</b>

## DOCUMENT REFERENCES

### TABLES

Table 1	Maximum Octave Band Noise Levels .....	4
Table 2	Identified Receptors – Girrawheen FCS (GFCS).....	12
Table 3	EPP(Noise) Acoustic Quality Objectives .....	14
Table 4	Deemed Background Noise Levels .....	15
Table 5	Best Practice Measured Outdoor Noise Emission Limits (DESI, 2024).....	16
Table 6	Project Noise Emission Limit Overview .....	16
Table 7	Noise Model Inputs .....	19
Table 8	Modelled Meteorological Conditions – Neutral and Adverse.....	19
Table 9	Operating Unit Maximum Plant SWLs.....	20
Table 10	Quantity of Noise Sources Modelled for Each Scenario .....	20
Table 11	Predicted Noise Level at Receptor – Normal Operations .....	22
Table 12	Maximum Sound Power Noise Levels for the Power Generation Units (Mitigated).....	23
Table 13	Predicted Noise Level at Receptor – Normal Operations with Mitigated Power Generation Units .....	24
Table 14	Predicted Noise Level at Receptor – Flaring .....	25
Table 15	Maximum Octave Band Noise Levels .....	28

### FIGURES

Figure 1	Proposed Girrawheen FCS Layout.....	10
Figure 2	Girrawheen FCS and Receptors.....	13
Figure 3	Indicative MPGF Fence (Image source: Zeeco) .....	21
Figure 4	Scenario 1 – Normal Operation Under Neutral Weather Conditions .....	2
Figure 5	Scenario 1 – Normal Operation Under Adverse Weather Conditions .....	2
Figure 6	Scenario 2 – MPGF Flaring Operating at 18% Under Neutral Weather Conditions .....	2
Figure 7	Scenario 2 – MPGF Flaring Operating at 36% Under Neutral Weather Conditions .....	2
Figure 8	Scenario 2 – MPGF Flaring Operating at ~53% Under Neutral Weather Conditions .....	2
Figure 9	Scenario 2 – MPGF Flaring Operating at 100% Under Neutral Weather Conditions .....	2
Figure 10	Scenario 2 – MPGF Flaring Operating at 18% Under Adverse Weather Conditions .....	2
Figure 11	Scenario 2 – MPGF Flaring Operating at 36% Under Adverse Weather Conditions .....	2
Figure 12	Scenario 2 – MPGF Flaring Operating at ~53% Under Adverse Weather Conditions .....	2
Figure 13	Scenario 2 – MPGF Flaring Operating at 100% Under Adverse Weather Conditions .....	2

## APPENDICES

Appendix A Acoustic Glossary

Appendix B Scenario 1 – Normal Operations Noise Contour Maps

Appendix C Scenario 2 – Flaring Noise Contour Maps

---

# 1 Introduction

SLR Consulting Australia Pty Ltd (SLR) has been engaged by Arrow Energy (Arrow) to undertake a noise assessment of the Girrawheen Field Compressor Station (FCS), which is located approximately 18 km north of Miles, Queensland.

## 1.1 Background

The Girrawheen FCS will facilitate the compression of low-pressure coal seam gas (CSG) and deliver medium-pressurised gas downstream to the gas sales delivery point. The facility consists of the following main processes:


- Screw compressors (up to four) which compress low-pressure coal seam gas (CSG),
- CSG fired internal combustion power generation plant equipped with a battery energy storage system (BESS). This provides electrical power to the facility mainly used to power the compressors.
- Multi-point ground flare (MPGF, to manage distressed gas),
- Slug catcher (to remove water in gas line; and
- Cyclone separator (to remove solids/fines in gas line).

The proposed Girrawheen FCS layout is shown in **Figure 1**.



## 1.2 Objectives of this Assessment

The objective of this noise impact assessment is to assess the potential for noise impact from the operation of the Girrawheen FCS. This noise assessment will be used to support an application for an Environmental Authority (EA) for the Girrawheen FCS.

Construction noise and vibration and gas field operational noise is covered in Arrow's noise and vibration management plan, document reference ORG-ARW-HSM-PLA-00043. This management plan includes Arrow's management framework that will be used to manage noise impacts for the Girrawheen FCS development. Therefore, construction noise and vibration is not covered in this assessment and reference should be made to the Arrow document ORG-ARW-HSM-PLA-00043 for construction noise and vibration management.



WIND ROSES



EQUIPMENT LIST

ITEM	DESCRIPTION	SIZE(mm)(LxWxH)	PACKAGE TAG
1	PIPERACK MODULE (A-G)	1800 x 4000	-
2	LUBE OIL INJECTION PACKAGE	3500 x 1750	00-A-0011
3	BOP SWITCHROOM	2100 x 2750	00-SWR-0002
4	COMPRESSION SWITCHROOM	2940x x 2750	00-SWR-0004
5	COMPRESSION SWITCHROOM	2940x x 2750	00-SWR-0003
6	GAS ANALYZER SKID	3048 x 2438	50-A-0002
7	HV SWITCHROOM	15000 x 3800	00-SWR-0001
8	DISTRIBUTION TRANSFORMERS	3500 x 1750	-
9	AIR COMPRESSOR PACKAGE	8400 x 3500	40-A-0001
10	PRODUCED WATER TRANSFER AND PUMP PACKAGE	1200 x 3000	00-A-0004
11A	SLUG CATCHER #1	1200 x 19870	SP-25-0001
11B	SLUG CATCHER #2	1200 x 19870	SP-25-0002
12	SLUG CATCHER DRAIN SKID PACKAGE	6777 x 2929	99-A-0001
13A	INLET FILTER SEPARATOR PACKAGE #1	-	00-A-0001
13B	INLET FILTER SEPARATOR PACKAGE #2	-	00-A-0002
14	MAIN COMPRESSOR PACKAGE #1	31600 x 8500	01-A-0001
15	MAIN COMPRESSOR PACKAGE #2	31600 x 8500	02-A-0001
16	MAIN COMPRESSOR PACKAGE #3	31600 x 8500	03-A-0001
17	MAIN COMPRESSOR PACKAGE #4	31600 x 8500	04-A-0001
18	TELECOMS TOWER AND BUILDING	-	-
19	GROUND FLARE PACKAGE	31100 x 45400	12-A-0002
20	FLARE CONTROL SKID	3600 x 1375	-
21	FLARE KNOCKOUT DRUM PACKAGE	10500 x 2625	12-A-0001
22	-	-	-
23	TREATED WATER EXPORT PUMP	-	00-P-0002A/B
24	TREATED WATER TANK	ø3573 x 2722	B-T-0006
25	OIL SEPARATION UNIT	5750 x 2625	00-A-0005
26	WASTE OIL TANK	1920 x 2278 x 601	00-T-0001
27	OPEN DRAIN SUMP (PURCEPTOR)	ø1800 x 5900	00-T-0002
28	SALES GAS METERING PACKAGE	32500 x 3500	50-A-0001
29	PIG LAUNCHER	-	-
30	LUBE OIL COALESCER PACKAGE	7818 x 2700	00-A-0003
31	ESSENTIAL DIESEL GENERATOR	16411 x 4064	-
32	DIESEL STORAGE TANK	-	-
33	LUNCHROOM AND ABLUTIONS (SELF CONTAINED)	12000 x 6075	-
34	-	-	-

**Equinox Engineering**  
Document Control  
**ISSUED FOR DESIGN**  
2024-05-16

- NOTES:
- PROPOSED LEASE BOUNDARY IS SHOWN SEE SET OUT POINTS TABLE FOR LOCATION.
  - EXPORT GAS PIPELINE, TREATED AND CLEAN PRODUCED WATER PIPELINE AND GATHERING NETWORK PIPELINE ALIGNMENT ROUTING IS INDICATIVE WITH DESIGN BY OTHERS. PRELIMINARY ROUTING SHOWN FOR INFORMATION ONLY.
  - POWER STATION DESIGN BY OTHERS. SEE DRAWING 5000B1-ARW-CIV-LAY-00001.
  - WATER TRANSFER STATION DESIGN BY OTHERS.
  - COMMUNICATION TOWER COMPOUND BY OTHERS.
  - PLANT LOCATION: 26°30'15" S 150°37'12" E (GDA50, 150 2271 GEODETIC COORDINATES).
  - 15m MINIMUM FROM LUBE OIL COALESCER TO FUTURE PROPANE ACCUMULATOR VESSEL.
  - THE DESIGN FOR THE INTERFACE FOR THE PIPELINES ENTERING/LEAVING THE EAST SIDE OF THE FCS IS THE FENCE LINE.
- SCALE 1:1000  
EQUINOX PROJECT NO. 910-01-00

PLANT DATUM	PLANT	MOA 56 (00A2020)
NORTHING (m)	0+00.000	7065320.425
EASTING (m)	0+00.000	223355.586
ELEVATION (m)	95.158	312.336

SET OUT POINT 1	PLANT	MOA 56 (00A2020)
NORTHING (m)	0+500.000	7065320.425
EASTING (m)	1+457.552	223688.138
ELEVATION (m)	95.529	312.707

SET OUT POINT 2	PLANT	MOA 56 (00A2020)
NORTHING (m)	-0+38.816	7065281.610
EASTING (m)	1+452.252	223688.138
ELEVATION (m)	94.196	311.374

SET OUT POINT 3	PLANT	MOA 56 (00A2020)
NORTHING (m)	-0+38.000	7065281.425
EASTING (m)	2+84.900	223820.486
ELEVATION (m)	92.397	309.575

SET OUT POINT 4	PLANT	MOA 56 (00A2020)
NORTHING (m)	0+89.898	7065410.323
EASTING (m)	2+84.900	223820.486
ELEVATION (m)	94.671	311.849

SET OUT POINT 5	PLANT	MOA 56 (00A2020)
NORTHING (m)	3+86.800	7065717.225
EASTING (m)	4+37.108	223972.694
ELEVATION (m)	95.322	312.500

SET OUT POINT 6	PLANT	MOA 56 (00A2020)
NORTHING (m)	3+496.800	7065717.225
EASTING (m)	0+445.600	223601.194
ELEVATION (m)	101.307	316.485

SET OUT POINT 7	PLANT	MOA 56 (00A2020)
NORTHING (m)	3+445.480	7065665.906
EASTING (m)	0+465.600	223601.196
ELEVATION (m)	100.688	317.846

SET OUT POINT 8	PLANT	MOA 56 (00A2020)
NORTHING (m)	4+223.242	7065743.667
EASTING (m)	-1+451.161	223434.528
ELEVATION (m)	99.982	317.160

SET OUT POINT 9	PLANT	MOA 56 (00A2020)
NORTHING (m)	2+82.311	7065602.736
EASTING (m)	-1+468.878	223688.708
ELEVATION (m)	99.315	314.493

SET OUT POINT 10	PLANT	MOA 56 (00A2020)
NORTHING (m)	2+404.495	7065244.920
EASTING (m)	0+400.000	223335.586
ELEVATION (m)	97.919	315.097


A. ASSUMED PLANT EL. 100.000m = GEODETIC EL. 317.78m  
 B. ELEVATIONS SHOWN ARE GROUND (FROM LIDAR).  
 C. SCALE FACTOR NOT PROVIDED IN SURVEY.

NO.	DATE	ISSUED FOR DESIGN	CA	AF	KT	PP	RPED	CERTIFICATION
F	02/05/24	ISSUED FOR DESIGN	CA	AF	KT	PP	RPED	CERTIFICATION
D	01/02/23	ISSUED FOR DESIGN	MN	AF	BT	BT		
C	31/03/23	ISSUED FOR DESIGN	MN	AF	BT	BT		
B	02/02/23	ISSUED FOR DESIGN	CA	AF	PF	PF		
A	14/11/22	ISSUED FOR APPROVAL	RJM	RF	AF	PF	REP NO. /	

REFERENCE DRAWING NUMBER	REFERENCE DRAWING TITLE	REV	DATE	REVISION DESCRIPTION
SCAN01-ARW-CIV-LAY-00024	OVERALL EARTHWORKS LAYOUT			
SCAN01-ARW-ENG-DET-00002	MBS PLAN			
SCAN01-ARW-ENG-SSP-00002	ESCAPE PLAN			

		SITE SCA	PLANT NO1	PROJECT CODE A275	<b>CASTLEDAN</b> GIRRAHREEN FIELD WATER TREATMENT PLANT SURAT GAS PROJECT PLOT PLAN LAYOUT
		SECURITY CLASSIFICATION	RESTRICTED	ARROW ENERGY DRAWING NUMBER	
STATUS / I/FUD		CONTRACTOR DRAWING NUMBER		SCALE 1:1000	REV F
DATE 02/05/24		DATE 02/05/24		SCALE	REV F



DO NOT SCALE - IF IN DOUBT - ASK

THRO ANGLE PROJECTION

UNLESS OTHERWISE STATED, FABRICATION TOLERANCES TO BE:

< 500mm	± 1mm
500mm-1500mm	± 2mm
> 1500mm	± 3mm
0.0	± 0.5mm
ANGULAR	± 1°

WEIGHT: est. \_\_\_\_\_ kg, act. \_\_\_\_\_ kg

NOTE:

- REPORT ALL ERRORS TO ENGINEERING.
- ALL BUILD MODIFICATIONS & CHANGES TO BE NOTIFIED TO ENGINEERING.
- UNLESS OTHERWISE STATED, ALL DIMENSIONS IN MILLIMETRES.
- ALL ERRORS TO BE MARKED ON DRAWING IN RED INK ONLY.

REV	DATE	DESCRIPTION
A	04/02/2024	INITIAL ISSUE FOR TENDER
B	25/04/2024	REDUCED BESS, REMOVED SC & ADDED DATUM PT

- NOTES:
- ALL DIMENSIONS ARE IN MM.
  - THE POSITION OF ALL EQUIPMENT IS NOMINAL.
  - CABLE LADDER:
    - TO BE NEMA 3 (20B)
    - CABLE LADDER COVERS TO BE CHECKERED PLATE ALUMINIUM OR AS PER SITE REQUIREMENTS.
    - CABLE LADDER RUNS ON 75mm x 50mm GALVANISED RHS UNDERNEATH ALL EQUIPMENT.
  - MINIMUM 5.5m CLEARANCE REQUIRED AT ALTERNATOR END OF GENERATOR FOR SERVICING.
  - S/S OIL PIPING TO RUN IN 300mm CABLE LADDER FOR MECHANICAL PROTECTION.
  - HV SWITCHROOM, EARTHING TRANSFORMERS, LOAD BANK (FOR COMMISSIONING) ARE INDICATIVE ONLY.
  - LAYOUT IS SUBJECT TO FURTHER ENGINEERING DESIGN.
  - BESS SIZE TO BE CONFIRMED.

- KEY:
- PERIMETER
  - GAS PIPE
  - OIL PIPE
  - DIESEL PIPE
  - ELECTRICAL CONDUIT UNDERGROUND
  - ES# EXHAUST STACK DATUM POINT

EXHAUST STACK CO-ORDINATES RELATIVE TO MGA56 (GDA2020)

POINT ID	EASTING	NORTHING
ES1	223644380	7065401538
ES2	2236449318	7065401538
ES3	223665132	7065401538
ES4	223670070	7065401538
ES5	223675008	7065401538
ES6	223679946	7065401538
ES7	2236895760	7065401538
ES8	223700698	7065401538
ES9	223705636	7065401538
ES10	223710574	7065401538
ES11	223726388	7065401538
ES12	223731326	7065401538
ES13	223644380	7065382741
ES14	2236449318	7065382741
ES15	223665132	7065382741
ES16	223670070	7065382741
ES17	223675008	7065382741
ES18	223679946	7065382741

NOTE: CO-ORDINATES ARE GIVEN IN MILLIMETRES

PART No.

WORK TO	STANDARDS
A.S.1	- DATUMS & DIMENSIONING
A.S.2	- LD OF BOUGHT IN FABRICATIONS.
A.S.3	- PAINTING & COATING.
A.S.4	- WELDING.
A.S.5	- CONTROL PANEL WIRING.
A.S.6	- PRESSURE TESTING.
A.S.7	- MATERIAL SPEC. & GRADE.
A.S.8	- SLENER SPECIFICATION.
A.S.9	- ELECTROPLATING SPECIFICATION.

TITLE: ARROW ENERGY GIRRHEEN GIRRRAHWEEN FIELD COMPRESSION STN.(FCS) POWER STATION - SITE LAYOUT

JOB NO. 23225

CUSTOMER REF. P/O. ARROW ENERGY

SCALE 1:450 SIZE A3

DRG. NO. 23225-DWG-L0-01 SHEET NO. 1 OF 1 REV. B

---

## 2 Site Description

### 2.1 Site Location

Girrawheen FCS is located in the Surat Basin approximately 18 km north of Miles in the Darling Downs region of Queensland in predominantly rural land.

Areas where Arrow has tenure are predominantly rural and industrial with land uses such as grazing, pre-existing gas field development and overlapping mining tenure. Existing road infrastructure typically includes a number of rural secondary roads linking the major regional road network as well as numerous CSG field access roads and mining activities.

### 2.2 Sensitive Receptors

The DES guideline, *Streamlined Model Conditions for Petroleum Activities (DES, 2016)* defines sensitive receptors as follows:

*A sensitive place could include but is not limited to:*

- *A dwelling, residential allotment, mobile home or caravan park, residential marina or other residential premises;*
- *A motel, hotel or hostel;*
- *A kindergarten, school, university or other educational institution;*
- *A medical centre or hospital;*
- *A protected area under the Nature Conservation Act 1992, the Marine Parks Act 2004 or a World Heritage Area;*
- *A public park or garden; and*
- *A place used as a workplace including an office for business or commercial purposes.*

Information on sensitive receptors located in and around the Project was provided by Arrow. Those receptors identified as being located within 9 km of the Girrawheen FCS are listed in **Table 2** and shown in **Figure 2**.

**Table 2 Identified Receptors – Girrawheen FCS (GFCS)**

Receptor ID	Coordinates (GDA 94 zone 56)		Receptor ID	Coordinates (GDA 94 zone 56)	
	Easting	Northing		Easting	Northing
GFCS-1	222,680	7,068,507	GFCS-10	218,243	7,067,196
GFCS-2	220,766	7,064,862	GFCS-11	218,247	7,064,078
GFCS-3	220,144	7,067,178	GFCS-12	228,263	7,064,589
GFCS-4	220,272	7,064,803	GFCS-13	228,626	7,065,108
GFCS-5	220,584	7,063,619	GFCS-14	226,966	7,061,991
GFCS-6	220,381	7,063,139	GFCS-15	227,791	7,062,623
GFCS-7	219,152	7,064,353	GFCS-16	220,018	7,061,057
GFCS-8	220,013	7,062,935	GFCS-17	227,278	7,061,081
GFCS-9	218,668	7,068,376	GFCS-18	217,814	7,072,105

## 2.3 Existing Noise Environment

Girrawheen FCS site and surroundings is predominantly rural with land uses such as grazing and pre-existing gas field development. Existing infrastructure typically includes a number of rural secondary roads linking the major regional road network as well as numerous CSG field access roads. Existing noise sources are generally typical of rural roads and include fauna (birds and insects), traffic and local sources associated with mining activity and rural based human occupation.

## 2.4 Background Noise Levels

The Project has not undertaken site specific background noise monitoring for the purpose of varying the deemed minimum background noise levels as stated in *Prescribing noise conditions for environmental authorities for petroleum activities* Guideline (DESI Guideline, 2024).

Based on SLRs experience in conducting site specific background noise measurements in Queensland’s CSG fields and rural areas, measured background noise levels at noise sensitive receptors are routinely equal to or lower than the deemed background noise levels. This is generally due to ‘natural’ intermittent noise sources (ie bird song, wind and wind generated vegetation noise, seasonal insects) controlling the sound scape. During the most sensitive night-time periods, these ‘natural’ sources are often either infrequently measured or are not present for periods of time, therefore the background noise level is routinely below the deemed minimum background noise level of 25 dBA LA90.

For this assessment, the Project has adopted the deemed minimum background noise levels specified in DESI Guideline in lieu of site specific noise monitoring and is considered applicable given the rural nature of the Girrawheen FCS area and expected low background noise levels within this area.



H:\Projects\SLR\620-BNE\620-12248-Arrow Energy - Project Pearl\06.SLR>Data\01\_CAD\GIS\Map\GIS\62012248\_F02\_Girrawheen FCS and Receptor\_Location\_002.mxd

**LEGEND**  
 ○ Receptors  
 ■ Infrastructure Site

0 0.5 1 km

Scale: 1:60,000 at A4  
 Coordinate System: GDA 1994 MGA Zone 56

Date Drawn: 24-Jun-2024  
 Project Number: 620.12248.01600



Data Source:  
 ESRI basemap world imagery (May 2023)

**Arrow Energy  
 Girrawheen FCS and Receptor  
 Location**

**FIGURE 2**

### 3 Regulatory Framework

The following section outlines the regulatory framework in which the Girrawheen FCS noise assessment has been performed.

#### 3.1 Queensland Noise Regulations

The Environmental Protection (Noise) Policy 2019 (EPP (Noise)) is subordinate legislation under the Queensland Environmental Protection (EP) Act and the environmental values to be enhanced or protected under the EPP(Noise) are:

- The qualities of the acoustic environment that are conducive to protecting the health and biodiversity of ecosystems.
- The qualities of the acoustic environment that are conducive to human health and wellbeing, including by ensuring a suitable acoustic environment for individuals to do any of the following: sleep, study or learn or be involved in recreation, including relaxation and conversation.
- The qualities of the acoustic environment which are conducive to protecting the amenity of the community.

The EPP(Noise) contains Acoustic Quality Objectives (AQO) for receptors potentially sensitive to noise. Where the overall level of noise at the receptors, from all sources but excluding road and rail transport noise, are within the AQO, the environmental values are considered to be achieved.

The AQO for the noise sensitive receptors and land use surrounding the Project are presented in **Table 3**. Project operations require continuous operation of plant as such this Assessment has referenced the 1-hour LAeq and LA1 AQO to assess the noise emissions from Project noise sources.

**Table 3 EPP(Noise) Acoustic Quality Objectives**

Receptor Type	Time of Day	Acoustic Quality Objective (dBA)		
		LAeq,adj,1hr	LA10adj,1hr	LA1,adj,1hr
Residential dwelling (outdoors)	Day time and evening	50	55	65
Residential dwelling (indoors)	Daytime and evening	35	40	45
	Night-time	30	35	40

To assess noise levels to the internal (indoor) AQO at residential dwellings, the external noise levels predicted by the noise modelling are adjusted by a façade correction which accounts for the reduction of noise achieved by the building (with windows open). In this Assessment, a conservative 7 dB façade noise reduction has been applied in line with the DES guideline titled ‘Noise and Vibration EIS Information Guideline’, where, at page 3, it states:

*When assessing outdoor to indoor noise attenuation at sensitive receptors ... use an outdoor to indoor attenuation value of 7dB, which is appropriate for typical Queensland buildings with open windows.*

Accordingly, internal residential noise levels would be expected to be within the indoor AQO where external noise levels are not more than:

- LAeq,adj,1hr 42 dB during the daytime and evening.

- LAeq,adj,1hr 37 dB during the night-time.
- LA1,adj,1hr 52 dB during the daytime and evening.
- LA1,adj,1hr 47 dB during the night-time.

## 3.2 DESI Guideline - Prescribing Noise Conditions for Petroleum and Gas Activities

The Queensland Departments of Environment, Science and Innovation (DESI) has published a noise assessment guideline entitled *Prescribing noise conditions for environmental authorities for petroleum activities* (DESI Guideline, 2024), which is intended to assist in the assessment of noise impacts and the development of noise conditions for petroleum activities within the general framework provided by the EP Act.

This guideline addresses noise management and includes best practice noise emission limits for CSG activities.

### 3.2.1 Deemed Background Noise Levels

In accordance with the DESI Guideline, there are deemed background noise levels to be used in the determination of noise limits/criteria in rural areas where background noise levels can be very low. The intent of the deemed background noise levels are to achieve a balance between economic development and environmental protection required by the EP Act. Deemed background noise levels are to be applied where site specific noise monitoring has not been undertaken.

The Project has adopted the deemed background noise levels presented in **Table 4**.

**Table 4** Deemed Background Noise Levels

Time Period	Deemed Background Noise Level (dBA)
7:00 am – 6:00 pm (day)	35
6:00 pm – 10:00 pm (evening)	30
10:00 pm – 6:00 am (night)	25
6:00 am – 7:00 am (morning)	30

Note 1: Referenced from *Table 2 – Deemed background noise levels, page 8 (DESI Guideline 2024)*.

### 3.2.2 Noise Limits

The guideline noise limits are designed to protect the acoustic values of a sensitive receptor in rural or isolated areas and to satisfy the acoustic quality objectives of the EPP (Noise) whilst considering cumulative impacts and background creep.

Best practice measured noise emission limits for long term noise exposure applicable to the Surat Basin from the guideline (DESI Guideline, 2024) for each of the specified daily time periods are provided in **Table 5**. These noise limits closely align with the 'Streamlined Conditions' contained within the DESI *Streamlined Model Conditions for Petroleum Activities* (DESI Guideline, 2024), effective 13 May 2024 (hereafter referred to as SMC).

**Table 5 Best Practice Measured Outdoor Noise Emission Limits (DESI, 2024)**

Time Period	Time of Day	Metric	Long Term Noise Limit, dBA <sup>2</sup>
7:00 am – 6:00 pm	Daytime	LAeq, adj, 15 minutes	40 (LABG + 5)
6:00 pm – 10:00 pm	Evening	LAeq, adj, 15 minutes	35 (LABG + 5)
10:00 pm – 6:00 am	Night-time	LAeq, adj, 15 minutes	28 (LABG + 3)
		Max LpA, 15 minutes	55
6:00 am – 7:00 am	Morning	LAeq, adj, 15 minutes	35 (LABG + 5)

Note 1: Referenced from Table 5 – Best practice measured noise emission limits, page 13 (DESI Guideline 2024).

Note 2: LABG is the deemed background noise levels which are:

- 7:00 am – 6:00 pm: 35 dBA
- 6:00 pm – 10:00 pm: 30 dBA
- 10:00 pm – 6:00 am: 25 dBA
- 6:00 am – 7:00 am: 30 dBA

The night period is considered the most critical daily period in respect to noise compliance. Compliance with the long-term night noise limit for operating plant and equipment will ensure compliance with the noise limit for all other daily periods.

### 3.2.3 Low Frequency Noise

The SMC contains the following emission limits for low frequency noise, which are relevant to the Project:

- 60 dBC measured outside the sensitive receptor; and
- The difference between the external A-weighted and C-weighted noise levels is no greater than 20 dB.

## 3.3 Summary of Project Noise Conditions

In summary, the nominated noise limits that are considered appropriate for this noise assessment are summarised in **Table 6**. Reference to the EPP (Noise) AQO is provided for the purpose of comparison to other noise legislation in Queensland.

**Table 6 Project Noise Emission Limit Overview**

Time Period	Time of Day	Metric	Long Term Noise Limit, dBA
7:00 am – 6:00 pm	Daytime	LAeq, adj, 15 minutes	40 (35 <sup>1</sup> + 5)
6:00 pm – 10:00 pm	Evening	LAeq, adj, 15 minutes	35 (30 <sup>1</sup> + 5)
10:00 pm – 6:00 am	Night-time	LAeq, adj, 15 minutes	28 (25 <sup>1</sup> + 3)
		Max LpA, 15 minutes	55
6:00 am – 7:00 am	Morning	LAeq, adj, 15 minutes	35 (30 <sup>1</sup> + 5)

Note 1: LABG is the deemed background noise levels which are:

- 7:00 am – 6:00 pm: 35 dBA
- 6:00 pm – 10:00 pm: 30 dBA
- 10:00 pm – 6:00 am: 25 dBA
- 6:00 am – 7:00 am: 30 dBA

The emission of any low frequency noise must not exceed:

- 60 dBC measured outside the sensitive receptor, and
- The difference between the external A-weighted and C-weighted noise levels is no greater than 20 dB.

## 4 Girrawheen FCS Operational Noise Assessment

### 4.1 Assessed Operational Scenarios

The Girrawheen FCS has been assessed for the following operating scenarios:

- Scenario 1 – Normal Operation at maximum operating capacity
  - Four (4) Howden 510 screw compressors running at 2,000 RPM with coolers, and
  - Sixteen (16) operating CSG fired power station (internal combustion engines) and two (2) spare 1875 kVA Aggreko GE J420E units with BESS.
  - Two (2) Centrifugal pumps.
- Scenario 2 – Flaring
  - MPGF to occur under four (4) separate flare flow rates being 163 MMscfd, 87MMscfd, 58 MMscfd and 29 MMscfd.

Scenario 1 is typical of 24 hours 7 days operation and is considered normal operation which is likely to be constant and potentially audible during any period of the day.

Scenario 2 assesses flaring which occurs when a compressor trips or downstream capacity is restricted such that the gas being delivered to the facility (Girrawheen FCS) exceeds the delivery capacity. In these situations, gas must be flared until the well field can be turned down or compression/delivery capacity is restored. Flaring of gas occurs on rare occasions and is minimised to as low as reasonably practical (ALARP) through Arrow's advanced gas management (further information is outlined below). The occurrence of flaring events are not scheduled (ie not limited to daytime only). Flaring during scheduled events, such as annual maintenance activities can be scheduled to occur during the day and gas flow is minimised to reduce gas loss (maximum flare rates do not occur on a scheduled basis).

A range of flare flow rates has been assessed, representing typical ranges for flaring events that may be experienced at the facility. Arrow has provided the following additional information regarding the facilities flaring flows rates:

- For approximately 88% of the time over an hourly period, no flaring is expected to occur (ie no flare noise from the facility).
- 95% of flaring events are predicted to be less than 29 MMscfd (or 9.5% of the time during an hourly period).
- Flaring events greater than 29 MMscfd are expected to occur approximately 2% of the time over an hourly period (<1% at night-time).

Flare flow rates between 58 MMscfd and 163 MMscfd have been used to assess the worst-case noise potential during the rare occurrence of maximum flare flow rate that may be experienced at the Girrawheen FCS. The assessment has considered the potential for a worst-case scenario where flaring occurs for a minimum 15-minute duration during any assessable period (day, evening and night). This is considered a conservative approach and should be considered along with the expected frequency of each flaring event.

The Girrawheen FCS incorporates several noise abatement technologies to reduce noise emissions including:

- FCS Compressors:
  - Compressor enclosures with acoustic lining to minimise noise emissions.
- FCS Engines:
  - Engine enclosures to minimise noise emissions,
  - Acoustically treated louvres on air intakes, and
  - Exhaust silencers.
- Flare noise:
  - The use of a MPGF with a radiation fence has been selected over an elevated flare or sonic tip ground flare due to the reduced noise levels (when noise level output is compared) and therefore, minimizing the potential for flare noise impact.

This noise assessment assesses the residual noise impact after the noise abatement techniques have been applied to avoid the potential for noise impact.

## 4.2 Noise Modelling

### 4.2.1 Noise Modelling Methodology

In order to predict noise emission levels for the Girrawheen FCS, a SoundPLAN (Version 8.2) environmental computer model was used. SoundPLAN is a software package which enables compilation of a sophisticated computer model comprising a digitised ground map (containing ground contours and buildings), the location and acoustic SWL of the noise sources, namely Howden 510 screw compressors with coolers, CSG fired power station (internal combustion engines) and MPGF on site and the location of receivers for assessment purposes.

The computer model can generate noise emission levels taking into account such factors as the source sound power levels and locations, distance attenuation, ground absorption, air absorption and shielding attenuation, as well as meteorological conditions, including wind effects.

For this assessment, 3D terrain data, Girrawheen FCS and sensitive receptor locations were incorporated into the noise model to predict noise emissions at nearby noise sensitive receptors.

All noise sources were modelled in a central position (containing all acoustic energy) with noise levels predicted to determine if compliance with the noise limit stated in **Section 3.3** is achieved. The terrain is considered mostly 'flat' and predominately vegetated; thus, the noise model has incorporated 'soft' ground absorption factor of 1.0, which is typical for Arrow noise assessments determined through model calibration.

## 4.2.2 Noise Model Inputs

A summary of the noise model inputs considered in the assessment are provided in **Table 7**.

**Table 7 Noise Model Inputs**

Inputs	Model Type	Comments
Receivers	Single Point Receivers (SPR)	SPR were modelled 1.5m above ground level in close proximity to the dwellings/noise sensitive receivers.
Terrain	3-D Digital Ground Model (DGM)	3-D terrain data has been supplied by Arrow and digitised in SoundPLAN for assessment.
Ground Absorption	Ground Absorption Area, 1.0	The Project is predominately surrounded by vegetation and grass with dirt access tracks, therefore, has been modelled as 'soft' ground, which is typical for Arrow noise assessments for rural areas of this nature.
Calculation Method	CONCAWE	Refer to <b>Section 4.2.3</b> for the adopted model calculation method.
Meteorological Conditions	Both neutral and adverse weather conditions modelled	Refer to <b>Section 4.3</b> for the modelled weather conditions. Adverse weather conditions are representative of temperature inversions.
Noise Sources	Single Point Noise Source	Refer to <b>Section 4.4</b> for the modelled noise sources considered in the assessment.

## 4.2.3 Calculation Method – CONCAWE

The CONCAWE prediction methodology was utilised within SoundPLAN. The CONCAWE prediction method is specially designed for large facilities and incorporates the influence of wind effects and the stability of the atmosphere. The statistical accuracy of environmental noise predictions using CONCAWE was investigated by Marsh (Applied Acoustics 15 - 1982). Marsh concluded that CONCAWE was accurate to  $\pm 2$  dBA in any one octave band between 63 Hz and 4 kHz and  $\pm 1$  dBA overall.

## 4.3 Assessed Meteorological Conditions

For this assessment, consideration was given to the effects of both neutral and adverse meteorological conditions (wind, temperature, humidity and temperature inversions) on noise propagation during Girrawheen FCS operations. These neutral and adverse meteorological conditions are consistent with historical Arrow noise assessments and outlined in **Table 8**.

**Table 8 Modelled Meteorological Conditions – Neutral and Adverse**

Weather Parameter	Neutral Condition	Adverse Condition
Temperature	19°C	13°C
Humidity	60%	86%
Pasquill Gifford Turner Stability Class	D	F
Wind Speed	0 m/s	2 m/s (source to receptor)

## 4.4 Modelled Plant Sound Power Levels

Modelled plant sound power levels (SWLs) for the Girrawheen FCS were provided by Arrow and are outlined in **Table 9**.

**Table 9 Operating Unit Maximum Plant SWLs**

Plant Items	Source Height above Ground	Sound Power Level, LAeq dBA									Overall SWL dBA
		Octave Band Centre Frequency (Hz)									
		31.5	63	125	250	500	1k	2k	4k	8k	
Power Generator Unit & Generator Engine Exhaust Aggreko GE J420E	2.0 m	71	90	106	97	92	93	85	82	74	<b>107</b>
Battery (BESS) 2.2 MWh unit	2.5 m	80	84	80	81	79	73	69	67	64	<b>88</b>
Inverter Transformer	2.5 m	84	85	86	86	81	79	77	82	76	<b>93</b>
Centrifugal Pumps	1.0 m	50	70	84	75	78	85	91	92	80	<b>96</b>
Mitigated Howden Screw Compressor Unit (fitted with acoustic panels)	2.0 m	71	76	84	101	99	95	92	87	78	<b>104</b>
Screw Compressor Coolers	1.5 m	73	87	96	100	101	101	95	91	83	<b>107</b>
Multi-Point Flaring 163 MMscfd	5.0 m	94	111	120	126	128	129	127	120	119	<b>134</b>
Multi-Point Flaring 87 MMscfd		90	107	116	122	124	125	123	116	115	<b>130</b>
Multi-Point Flaring 58 MMscfd		86	103	112	118	120	121	119	112	111	<b>126</b>
Multi-Point Flaring 29 MMscfd		84	101	110	116	118	119	117	110	109	<b>124</b>

The number of sources modelled for each scenario are shown in **Table 10**.

**Table 10 Quantity of Noise Sources Modelled for Each Scenario**

Plant Items	Modelled Noise Source Location/Coordinates, General Plant Locality Representative of Each Plant Area GDA2020		Number of Plant at Girrawheen FCS				
			Scenario 1 – Normal operations	Scenario 2 – Flaring <sup>1</sup>			
				Assessed Flare Flow Rates (MMscfd)			
X, m	Y, m	29	58	87	163		
Power Generator Unit & Generator Engine Exhaust Aggreko GE J420E	223692.18	7065369.16	16	13	10	7	4

Plant Items	Modelled Noise Source Location/Coordinates, General Plant Locality Representative of Each Plant Area GDA2020		Number of Plant at Girrawheen FCS				
			Scenario 1 – Normal operations	Scenario 2 – Flaring <sup>1</sup>			
	X, m	Y, m		Assessed Flare Flow Rates (MMscfd)			
			29	58	87	163	
Battery (BESS) 2.2 MWh unit	223746.88	7065339.19	6	6	6	6	6
Inverter Transformer	223751.99	7065329.86	3	3	3	3	3
Centrifugal Pumps	223494.00	7065544.00	2	2	2	2	2
Mitigated Howden Screw Compressor Unit (fitted with acoustic panels)	223680.03	7065632.87	4	3	2	1	0
Screw Compressor Cooling Towers	223663.86	7065633.29	4	3	2	1	0
Multi-Point Ground Flare (for all flaring rates)	223604.02	7065474.24	0	1	1	1	1

Note 1: Plant items are switched off depending on the flaring event.

#### 4.4.1 Multi-point Ground Flare Radiation Fence

The MPGF is expected to feature a 16.7 m radiation fence surrounding the flare in order to:

- Minimize radiation impacts, and
- Reduce visibility of the flare flame.

A typical MPGF fence is illustrated in **Figure 3**.

**Figure 3 Indicative MPGF Fence (Image source: Zeeco)**



The SWLs shown in **Table 9** for the MPGF do not include any potential noise reduction provide by the radiation fence. Arrow has provided SLR with a flare noise study report<sup>1</sup> outlining measured MPGF noise data with and without the inclusion of the fence at a separation distance of 50 m from the source.

From this study, SLR has derived an overall ‘flat’<sup>2</sup> 8.7 dB noise reduction correction from the measured Sound Pressure Levels (SPL) inside to outside of the radiation fence to determine the insertion loss. Therefore, the noise predictions have included the overall potential noise reduction when assessing the MGPF noise emissions at nearby sensitive receptors. This approach was preferred over constructing a physical barrier in SoundPLAN as the overlapping ventilation openings in the fence would not be possible to simulate in SoundPLAN.

## 4.5 Noise Assessment Results

### 4.5.1 Scenario 1 – Normal Operations

The noise model predicted noise emissions at nearby noise sensitive receptors when considering the Girrawheen FCS operating under ‘normal operations’ for both neutral and adverse weather. **Table 11** summarises the predicted noise levels at the surrounding identified noise sensitive receptors.

**Table 11 Predicted Noise Level at Receptor – Normal Operations**

Receptor ID	Predicted Noise Level at Receptor, LAeq dBA		Expected to Achieve 28 dBA <sup>1</sup> LAeq,15min Night-time Noise limits?
	Neutral Weather	Adverse Weather	
GFCS-1	25	30	No
GFCS-2	26	31	No
GFCS-3	23	28	Yes
GFCS-4	24	29	No
GFCS-5	24	29	No
GFCS-6	23	27	Yes
GFCS-7	21	25	Yes
GFCS-8	21	26	Yes
GFCS-9	18	23	Yes
GFCS-10	18	22	Yes
GFCS-11	19	23	Yes
GFCS-12	21	25	Yes
GFCS-13	20	25	Yes
GFCS-14	17	22	Yes
GFCS-15	20	25	Yes
GFCS-16	19	23	Yes

<sup>1</sup> GASCO Flare Noise Study report, document reference Q12551A-C01 Rev 0 *Surat Upstream Development, dated 15 August 2019.*

<sup>2</sup> Minimum noise reduction is achieved in all octave frequency bands.

Receptor ID	Predicted Noise Level at Receptor, LAeq dBA		Expected to Achieve 28 dBA <sup>1</sup> LAeq,15min Night-time Noise limits?
	Neutral Weather	Adverse Weather	
GFCS-17	19	23	Yes
GFCS-18	<15	18	Yes

Note 1: Compliance with the most stringent night-time 28 dBA LAeq, 15min noise criterion is expected to result in compliance with all other noise criteria.

Predicted noise levels presented in **Table 11** from Girrawheen FCS under ‘normal operations’ comply with the most stringent night-time noise limit of 28 dBA LAeq,15min under neutral weather and predominately adverse weather conditions. Under adverse weather conditions (only) up to four (4) dwellings are predicted to exceed the most stringent night-time noise limit of 28 dBA LAeq,15min with the most exposed receptor being GFCS-2, predicting 3 dBA above the 28 dBA LAeq,15min criterion. The dominant noise sources were found to be from the Power Generator Units. Noise mitigation is expected to be required in order to reduce the predicted noise exceedances under adverse weather conditions, refer to **Section 4.5.1.1** for further discussion.

Compliance with the most stringent night-time noise limit of 28 dBA LAeq,15min under both neutral and adverse weather conditions has also resulted in compliance with all other noise criteria outlined in **Table 11**. Compliance has also been predicted for all other criteria at receptors predicted to exceed the night-time noise limit of 28 dBA LAeq,15min under adverse weather conditions.

#### 4.5.1.1 Scenario 1 – Normal Operations Noise Mitigation Recommendation

Noise mitigation is required to achieve full compliance with the night-time noise limit of 28 dBA LAeq,15min under adverse weather conditions at all surrounding receptors. To achieve this outcome, SLR recommends that the sixteen (16) Power Generation Units with a sound power noise level of 107 dBA are designed to achieve a minimum 4 dBA noise reduction in all frequency octave bands (in particular 125 Hz and 250 Hz) to result in a maximum sound power noise level of 103 dBA per unit. Recommended noise attenuation to consider is engine exhaust silencer, air inlet silencer and/or acoustic enclosure for each proposed unit.

The Power Generation Units are required to achieve up to the maximum sound power noise levels in each frequency octave band (in particular 125 Hz and 250 Hz) shown in **Table 12**, to reach compliance with the night-time noise limit of 28 dBA LAeq,15min under both neutral and adverse weather conditions.

**Table 12 Maximum Sound Power Noise Levels for the Power Generation Units (Mitigated)**

Plant Items	Sound Power Level, LAeq dBA									Overall SWL dBA
	Octave Band Centre Frequency (Hz)									
	31.5	63	125	250	500	1k	2k	4k	8k	
Power Generator Unit, including Generator Engine Exhaust (Mitigated)	75	86	102	93	88	89	81	78	70	<b>103</b>

Revised noise predictions considering the sound power noise levels in **Table 12** are summarised in **Table 13** for all surrounding identified noise sensitive receptors.

**Table 13 Predicted Noise Level at Receptor – Normal Operations with Mitigated Power Generation Units**

Receptor ID	Predicted Noise Level at Receptor, LAeq dBA		Expected to Achieve 28 dBA <sup>1</sup> LAeq,15min Night-time Noise limits?
	Neutral Weather	Adverse Weather	
GFCS-1	22	27	Yes
GFCS-2	23	28	Yes
GFCS-3	20	25	Yes
GFCS-4	21	26	Yes
GFCS-5	21	26	Yes
GFCS-6	19	24	Yes
GFCS-7	17	22	Yes
GFCS-8	18	23	Yes
GFCS-9	15	19	Yes
GFCS-10	<15	19	Yes
GFCS-11	15	20	Yes
GFCS-12	17	22	Yes
GFCS-13	17	22	Yes
GFCS-14	<15	19	Yes
GFCS-15	17	22	Yes
GFCS-16	15	20	Yes
GFCS-17	15	20	Yes
GFCS-18	<15	<15	Yes

Note 1: Compliance with the most stringent night-time 28 dBA LAeq, 15min noise criterion is expected to result in compliance with all other noise criteria.

Mitigating the Power Generation Units noise levels by a minimum 4 dBA across all frequency octave bands would predict compliance against the most stringent night-time noise limit of 28 dBA LAeq,15min under both neutral and adverse weather conditions, and therefore, has also resulted in compliance with all other noise criteria outlined in **Table 11**.

No other design changes are deemed required for ‘normal operations’.

#### 4.5.2 Scenario 2 – Flaring

The noise model predicted noise emissions at nearby noise sensitive receptors when considering the Girrawheen FCS operating during a flaring event for both neutral and adverse weather. **Table 14** summarises the predicted noise levels at the surrounding identified noise sensitive receptors.

**Table 14 Predicted Noise Level at Receptor – Flaring**

Receptor ID	Predicted Noise Level at Receptor2, LAeq dBA							
	Considering Different MGP Flow Rates, MMscfd							
	163 (100%)	87 (~53%)	58 (36%)	29 (18%)	163 (100%)	87 (~53%)	58 (36%)	29 (18%)
	Neutral Weather				Adverse Weather			
GFCS-1	25	22	18	18	<b>32</b>	28	24	24
GFCS-2	27	23	19	16	<b>33</b>	<b>30</b>	26	23
GFCS-3	22	18	<15	15	<b>29</b>	25	21	21
GFCS-4	24	20	17	<15	<b>31</b>	27	23	21
GFCS-5	24	20	16	<15	<b>30</b>	26	22	19
GFCS-6	21	17	<15	<15	28	24	20	19
GFCS-7	19	15	<15	<15	25	21	18	17
GFCS-8	20	16	<15	<15	26	22	18	16
GFCS-9	15	<15	<15	<15	21	17	<15	15
GFCS-10	15	<15	<15	<15	21	17	<15	<15
GFCS-11	15	<15	<15	<15	22	18	<15	<15
GFCS-12	18	<15	<15	<15	25	21	17	<15
GFCS-13	17	<15	<15	<15	24	20	16	<15
GFCS-14	17	<15	<15	<15	24	20	16	<15
GFCS-15	17	<15	<15	<15	23	19	16	<15
GFCS-16	15	<15	<15	<15	21	17	<15	<15
GFCS-17	15	<15	<15	<15	21	17	<15	<15
GFCS-18	<15	<15	<15	<15	<15	<15	<15	<15

Note 1: Exceedance of 28 dBA LAeq,15min Night-time Noise limits are shown in **Bold**.

Note 2: Presented noise predictions include the derived 8.7 dB overall noise reduction to account for the noise screening of the radiation fence.

Predicted noise levels presented in **Table 14** from Girrawheen FCS during flaring predominately complies with all noise criteria outlined in **Table 11**, with the exception of the night-time noise criterion of 28 dBA LAeq,15min under adverse weather conditions (only). The dominant noise sources were found to be from the MGP in all operation modes.

Considering either unmitigated or mitigated Power Generation Units in the modelled flaring scenario's does not result in a predicted noise level change at the noise sensitive receptors; due to the flaring sound power noise levels being 17 dBA or greater than the Power Generation Units, resulting in the noise contribution from these units being negligible (during flaring events).

When assessing under adverse weather conditions compliance is expected to be achieved when flaring occurs up to a flow rate of 58 MMscfd. When considering the expected occurrence of flaring events this implies that 95% of all potential flaring events are predicted to result in noise levels below the proposed noise limits (in particular under adverse weather conditions).

Sensitive receptor GFCS-2 has predicted noise levels 2 dBA over the (most stringent) night-time noise limit of 28 dBA  $L_{Aeq,15min}$  during flow rates equal to 87 MMscfd. This flaring event is considered to be a rare occurrence, which is predicted to occur less than 1% of the time during an hour period and would be representative of a major sudden outage. All other receptors are considered to comply during flaring at a flow rate of 87 MMscfd, noting receptor GFCS-1 has predicted noise level equal to the night-time noise limit of 28 dBA  $L_{Aeq,15min}$ .

When assessed under maximum flare flow rates (163 MMscfd), up to five (5) sensitive receptors, being GFCS-1, GFCS-2, GFCS-3, GFCS-4 and GFCS-5 are predicted to potentially exceed the night-time noise limit of 28 dBA  $L_{Aeq,15min}$  when considering the maximum flare flow rate to occur during adverse weather conditions at each receptor. The possibility of the maximum flare flow rate event to occur during adverse weather ('source to receiver' wind conditions) could not occur at all receptors at the same time; therefore, predicted exceedances would only occur at the individual dwellings with the worst case being up to two receptors potentially exceeding at the same time, GFCS-2 and GFCS-4 due to similar locality.

All other nominated noise limits and receptor locations are expected to comply.

The noise predictions shown in **Table 14** include the derived overall 8.7 dB (flat) noise reduction correction to account for the proposed 16.7 m radiation fence. Any changes that would reduce the assessed 8.7 dB noise reduction from the fence would see the predicted noise levels increase at the receptor for the flaring scenario by an equal amount (1 dB reduction to the fence acoustic performance would equal a 1 dB increase to noise level predictions). It is also possible that the noise reduction due to the flare radiation fence is under-predicted in this assessment. If the noise reduction in the flare fence is greater than 8.7 dB, lower noise levels at the sensitive receptors would be expected for each flaring event.

## 4.6 Flare Noise Summary

The proposed MPGF is expected to achieve the nominated noise limits under the following parameters:

- A minimum 8.7 dB (flat) overall noise reduction is achieved by the 16.7 m radiation fence surrounding the MGPF.
- The Girrawheen FCS MPGF SWL does not exceed 126 dBA. This would result in achieving the night-time noise limit at all receptors under all weather conditions.

---

## 4.7 Low Frequency Noise Assessment

For the purposes of this assessment, the low frequency noise emissions have been analysed to assess for compliance with the nominated 60 dBC (external) low frequency noise limit. This review indicated that noise levels at the identified receptors were well below 55 dBC (external) and are therefore predicted to comply with the 60 dBC (external) low frequency noise limit for all modelling scenarios under all weather conditions.

This assessment incorporated all the sound power spectral information available at the time of modelling for all plant items.

## 5 Conclusion

SLR was commissioned by Arrow to undertake a noise assessment of the Girrawheen FCS development layout, which is proposed to be located approximately 18 km north of Miles, Queensland.

The Girrawheen FCS will incorporate several noise abatement technologies to reduce noise emissions including:

- FCS Compressors:
  - Compressor enclosures with acoustic lining to minimise compressor noise.
- FCS Engines
  - Engine enclosures to minimise generator noise.
  - Acoustically treated louvres on air intakes.
  - Exhaust silencers.
- Flare noise
  - The use of a MPGF with a radiation fence has been selected over an elevated flare or sonic tip ground flare due to the reduced noise levels (when compared) and therefore, minimizing the potential for flare noise impact.

This noise assessment assesses the residual noise emissions after the noise abatement techniques have been applied to reduce the potential noise impact onto surrounding receptors.

The Girrawheen FCS operational noise assessment identified the following:

- The proposed Girrawheen FCS development is expected to meet all nominated noise criteria outlined in **Section 3.3** for both assessed weather conditions when operating under 'normal operations' (Scenario 1) and the maximum sound power noise level of 103 dBA is achieved for the Power Generation Units.
  - The frequency octave band noise levels associated with the Power Generation Units and Screw Compressor Units are not to exceed those outlined in **Table 15**.

**Table 15 Maximum Octave Band Noise Levels**

Plant Items	Sound Power Level, LAeq dBA									Overall SWL dBA
	Octave Band Centre Frequency (Hz)									
	31.5	63	125	250	500	1k	2k	4k	8k	
Power Generator Unit, including Generator Engine Exhaust (Mitigated)	75	86	102	93	88	89	81	78	70	<b>103</b>
Mitigated Howden Screw Compressor Unit (fitted with acoustic panels)	71	76	84	101	99	95	92	87	78	<b>104</b>
Screw Compressor Coolers	73	87	96	100	101	101	95	91	83	<b>107</b>

- Predicted noise levels considering flaring noise from the MPGF in conjunction with other operating plant found the following:
  - Compliance at all receptors was achieved for all flare flow rates under neutral weather conditions.
  - Compliance at all receptors was achieved for all flare rates up to 58 MMscfd and under for all weather conditions. This represents 95% of expected flaring events that would potentially occur at the Girrawheen FCS.
  - At a flare flow rate of 87 MMscfd and above, marginal exceedance of the night-time noise limit of 28 dBA during adverse weather may occur at up to five (5) receptors. Noting, the worst case being up to two receptors too potentially exceed at the same time, GFCS-2 and GFCS-4 due to similar locality. All other receptors would be isolated occurrences.

The noise assessment included a minimum ‘flat’ overall 8.7 dB noise reduction to account for potential noise insertion loss from the 16.7 m radiation fence. Any change to the derived 8.7 dB noise reduction from the fence would see the predicted noise levels increase at the receptor for the flaring scenario (2) by an equal amount (1 dB reduction to the fences acoustic performance would equal a 1 dB increase to noise level predictions). It is also possible that the noise reduction due to the flare radiation fence is under-predicted in this assessment. If the noise reduction in the flare fence is greater than 8.7 dB, lower noise levels at the sensitive receptors would be expected for each flaring event.

# Appendix A:

## Acoustic Glossary

Explanation of the key technical terminology contained within this Report is provided below.

### Sound Level (or Noise Level)

The terms sound and noise are almost interchangeable, except that in common usage noise is often used to refer to unwanted sound.

Sound (or noise) consists of minute fluctuations in atmospheric pressure capable of evoking the sense of hearing. The human ear (and those of other species) responds to changes in sound pressure over a very wide range. The loudest sound pressure to which the human ear responds is ten million times greater than the softest. The decibel (dB or dBL) scale reduces this ratio to a more manageable size by the use of logarithms.

### A-weighted Sound Pressure Level

The overall level of a sound is usually expressed in terms of dBA, which is measured using a sound level meter with an 'A-weighting' filter. This is an electronic filter having a frequency response corresponding approximately to human hearing.

There are numerous alternative frequency weightings available but none specifically designed for the assessment of noise affecting fauna. For the purposes of this Report, A-weighting has been used.

### Sound Power Level

The sound power of a source is the rate at which it emits acoustic energy. As with sound pressure, sound power levels (SWL) are expressed in dB units, but are identified by the symbols SWL.

The relationship between sound power and sound pressure may be likened to an electric radiator, which is characterised by a power rating but has an effect on the surrounding environment that can be measured in terms of a different parameter, temperature.

### Change in Sound Pressure Levels

For human perception, a change of 1 dBA or 2 dBA in the level of a sound is considered to be indiscernible, while a 3 dBA to 5 dBA change corresponds to a small but noticeable change in loudness. A 10 dBA change corresponds to an approximate doubling or halving in loudness.

### Typical Sound Pressure Levels

The table below lists examples of typical sound pressure levels.

**Table**      **Examples of Typical Sound Pressure Levels**

Sound pressure level (dBA)	Typical example	Subjective (human) evaluation
130	Threshold of pain	Intolerable
120	Metal hammering	Extremely noisy
110	Grinding on steel	
100	Loud car horn at 3 metres (m)	Very noisy
90	Dog bark at 1 m	
80	Cicadas at 1 m	Loud
70	Noise level directly adjacent to a busy main road	


Sound pressure level (dBA)	Typical example	Subjective (human) evaluation
60	Ambient noise level in urban area close to main roads	Moderate to quiet
50	Typical rural environment with high insect noise or close to a main road	
40	Ambient noise level in a rural environment with light breezes and some noise from insects, birds and distant traffic	Quiet to very quiet
30	Ambient noise level in a typical rural noise environment in the absence of insect noise and wind	
20	Ambient noise level in remote and quiet rural environment away from main roads with no wind and no insect noise	Almost silent

### Statistical Noise Levels

Sounds that vary in level over time, such as road traffic noise and most community noise, are commonly described in terms of the statistical exceedance levels (LAN), where LAN is the A-weighted sound pressure level exceeded for N% of a given measurement period. For example, the LA1 is the noise level exceeded for 1% of the time and LA10 the noise level exceeded for 10% of the time.

The Figure below presents a hypothetical 15-minute noise measurement, illustrating various common statistical indices of interest.

**Figure Hypothetical 15 Minute Noise Measurement**



Of particular relevance to this study, are:

- LAeq The A-weighted equivalent noise level (basically the average noise level). It is defined as the steady sound level that contains the same amount of acoustical energy as the corresponding time-varying sound.
- LAmax The maximum A-weighted noise level during any given measurement period.

## Noise Propagation

Provided the receiver is in the far-field of the noise source, noise levels will reduce as a receiver moves further away from the source. This is due to spreading of the noise source energy over distance. For a simple point source (for example, a motor) the theoretical reduction in noise levels is 6 dBA per doubling of distance. For a line source (for example, a busy road) the theoretical reduction is 3 dBA per doubling of distance. In reality however other factors affect noise propagation. These include ground absorption, air absorption, acoustic screening and meteorological effects.

## Meteorological Effects

At distances over 500 m, meteorological affects (for example, local weather and atmospheric conditions) can substantially enhance or impair noise propagation. The most influential meteorological conditions on noise propagation are wind speed and direction and the occurrence of temperature inversions. Ambient air temperature and humidity and atmospheric pressure also affect noise propagation although to a lesser extent than wind and temperature inversions.

## Wind Conditions

Wind conditions enhance noise propagation when the wind is blowing from a noise source towards a receiver and therefore noise levels at the receiver will be higher under these conditions. The wind can be thought to carry the noise in the direction it is heading. Where winds blow from the receiver towards the source, the propagation of noise is impaired and therefore lower noise levels will be experienced at the receiver.

It is important to consider the effect of prevailing wind conditions when assessing noise propagation over larger distances. Wind roses, which graph long term variations in wind speed and direction, are a useful tool for analysing prevailing wind conditions where available.


## Temperature Inversions

Temperature inversions are a meteorological phenomenon where a layer of cold air is trapped at the ground surface under a layer of warmer air. Temperature inversions enhance noise propagation because sound travelling away from the ground is reflected back down from where the colder air meets the warmer air due to the change in pressure between the two layers.

Conditions that favour the development of a strong surface inversion are nights with calm winds and clear skies. Calm winds prevent warmer air above the surface from mixing down to the ground, and clear skies increase the rate of cooling at the Earth's surface. It is therefore important to consider the effect of temperature inversions when assessing noise propagation over larger distances and during night-time periods.

# Appendix B:

## Scenario 1 – Normal Operations Noise Contour Maps




**LEGEND**

- Receptors
- Infrastructure Site

**LAeq dBA Noise Level**

- 28
- 34
- 40
- 46
- 52
- 58



Scale: 1:60,000 at A4  
 Coordinate System: GDA 1994 MGA Zone 56

Date Drawn: 09-Jul-2024  
 Project Number: 620.12248.01600




Data Source:  
 ESRI basemap world imagery (May 2023)

**Arrow Energy**  
**Scenario 1 - Normal Operation Under**  
**Neutral Weather Conditions**


**FIGURE 4**

\\slr.local\Corporate\Projects\SLR\620-BNE\620.12248 Arrow Energy - Project\Peer\06 SLR Data\01 CAD\GIS\ArcGIS\620.12248\_Report2\_F04\_S1\_Girrawheen\_NormalOperation\_NeutralWeather\_001.mxd




# Appendix C:

## Scenario 2 – Flaring Noise Contour Maps



I:\u\_slr\local\Corporate\Projects\SLR\620-BNE\620-12248 Arrow Energy - Project\Peer\06 SLR Data\01 CAD\GIS\ArcGIS\62012248\_Report2\_F06\_S2\_Girrawheen\_MPGFFlaring05\_NeutralWeather\_001.mxd



Scale: 1:60,000 at A4  
 Coordinate System: GDA 1994 MGA Zone 56


Date Drawn: 09-Jul-2024  
 Project Number: 620.12248.01600



Data Source:  
 ESRI basemap world imagery (May 2023)

**Arrow Energy**  
**Scenario 2 - MPGF Flaring Operating at 18% Under Neutral Weather Conditions**

**FIGURE 6**



I:\u\_slr\local\Corporate\Projects\SLR\620-BNE\620-BNE\620-12248-Report2\_F07\_S2\_Girrawheen\_MPGFlaring50\_NeutralWeather\_001.mxd

**LEGEND**

- Receptors
- Infrastructure Site

**LAeq dBA Noise Level**

- 28
- 34
- 40
- 46
- 52
- 58


Scale: 1:60,000 at A4  
 Coordinate System: GDA 1994 MGA Zone 56  
 Date Drawn: 09-Jul-2024  
 Project Number: 620.12248.01600




Data Source:  
ESRI basemap world imagery (May 2023)

**Arrow Flaring**  
**Scenario 2 - MPGF Flaring Operating at 36% Under Neutral Weather Conditions**

**FIGURE 7**



I:\u\_slr\local\Corporate\Projects\SLR\620-BNE\620-12248 Arrow Energy - Project\Peer\06 SLR Data\01 CAD\GIS\ArcGIS\62012248\_Report2\_F09\_S2\_Girrawheen\_MPGFFlaring75\_NeutralWeather\_001.mxd



Scale: 1:60,000 at A4  
 Coordinate System: GDA 1994 MGA Zone 56


Date Drawn: 09-Jul-2024  
 Project Number: 620.12248.01600



Data Source:  
 ESRI basemap world imagery (May 2023)

**Arrow Energy**  
**Scenario 2 - MPG Flaring Operating at 53% Under Neutral Weather Conditions**

**FIGURE 8**



I:\u\_slr\local\Corporate\Projects\SLR\620-BNE\620.12248 Arrow Energy - Project\Peer\06 SLR Data\01 CAD\GIS\ArcGIS\620.12248\_Report2\_F09\_S2\_Girrawheen\_MPGFflaring100\_NeutralWeather\_001.mxd

**LEGEND**

- Receptors
- Infrastructure Site

**LAeq dBA Noise Level**

- 28
- 34
- 40
- 46
- 52
- 58


Scale: 1:60,000 at A4  
 Coordinate System: GDA 1994 MGA Zone 56  
 Date Drawn: 09-Jul-2024  
 Project Number: 620.12248.01600



Data Source:  
ESRI basemap world imagery (May 2023)

**Arrow Energy**  
**Scenario 2 - MPG Flaring Operating at 100% Under Neutral Weather Conditions**

**FIGURE 9**



I:\u.sr.local\Corporate\Projects\SLR\620-BNE\620.12248 Arrow Energy - Project\Peer\06 SLR Data\01 CAD\GIS\ArcGIS\620.12248\_Report2\_F10\_S2\_Girrawheen\_MPGFFlaring5\_AdverseWeather\_001.mxd

0 0.5 1 km

Scale: 1:60,000 at A4  
Coordinate System: GDA 1994 MGA Zone 56


Date Drawn: 09-Jul-2024  
Project Number: 620.12248.01600



Data Source:  
ESRI basemap world imagery (May 2023)

**Arrow Energy**  
**Scenario 2 - MPG Flaring Operating at 18% Under Adverse Weather Conditions**

**FIGURE 10**




I:\u\_slr\local\Corporate\Projects\SLR\620-BNE\620.12248 Arrow Energy - Project\Peer\06 SLR Data\01 CAD\GIS\ArcGIS\620.12248\_Report2\_F11\_S2\_Girrawheen\_MPGF\Flaring50\_AdverseWeather\_001.mxd

**LEGEND**

- Receptors
- Infrastructure Site

**LAeq dBA Noise Level**

- 28
- 34
- 40
- 46
- 52
- 58



Scale: 1:60,000 at A4  
 Coordinate System: GDA 1994 MGA Zone 56


Date Drawn: 09-Jul-2024  
 Project Number: 620.12248.01600



Data Source:  
 ESRI basemap world imagery (May 2023)

**Arrow Energy**  
**Scenario 2 - MPG Flaring Operating at 36% Under Adverse Weather Conditions**

**FIGURE 11**




I:\u.slr\local\Corporate\Projects\SLR\620-BNE\620.12248 Arrow Energy - Project\Peer\06 SLR Data\01 CAD\GIS\ArcGIS\620.12248\_Report2\_F12\_S2\_Girrawheen\_MPGFFlaring75\_AdverseWeather\_001.mxd



Data Source:  
 ESRI basemap world imagery (May 2023)

**Arrow Energy**  
**Scenario 2 - MPG Flaring Operating at 53% Under Adverse Weather Conditions**

**FIGURE 12**



I:\u.slr.local\Corporate\Projects\SLR\620-BNE\620.12248 Arrow Energy - Project\Peer\06 SLR Data\01 CAD\GIS\ArcGIS\620.12248\_Report2\_F13\_S2\_Girrawheen\_MPGFlaring100\_AdverseWeather\_001.mxd



Data Source:  
 ESRI basemap world imagery (May 2023)

**Arrow Energy**  
**Scenario 2 - MPG Flaring Operating at 100% Under Adverse Weather Conditions**

**FIGURE 13**

## ASIA PACIFIC OFFICES

### ADELAIDE

60 Halifax Street  
Adelaide SA 5000  
Australia  
T: +61 431 516 449  
E: [adelaide@slrconsulting.com](mailto:adelaide@slrconsulting.com)

### DARWIN

Unit 5, 21 Parap Road  
Parap NT 0820  
Australia  
T: +61 8 8998 0100  
E: [darwin@slrconsulting.com](mailto:darwin@slrconsulting.com)

### NEWCASTLE

10 Kings Road  
New Lambton NSW 2305  
Australia  
T: +61 2 4037 3200  
E: [newcastleau@slrconsulting.com](mailto:newcastleau@slrconsulting.com)

### TOWNSVILLE

12 Cannan Street  
South Townsville QLD 4810  
Australia  
T: +61 7 4722 8000  
E: [townsville@slrconsulting.com](mailto:townsville@slrconsulting.com)

### AUCKLAND

201 Victoria Street West  
Auckland 1010  
New Zealand  
T: 0800 757 695  
E: [auckland@slrconsulting.com](mailto:auckland@slrconsulting.com)

### SINGAPORE

39b Craig Road  
Singapore 089677  
T: +65 6822 2203  
E: [singapore@slrconsulting.com](mailto:singapore@slrconsulting.com)

### BRISBANE

Level 16, 175 Eagle Street  
Brisbane QLD 4000  
Australia  
T: +61 7 3858 4800  
E: [brisbane@slrconsulting.com](mailto:brisbane@slrconsulting.com)

### GOLD COAST

Level 2, 194 Varsity Parade  
Varsity Lakes QLD 4227  
Australia  
M: +61 438 763 516  
E: [goldcoast@slrconsulting.com](mailto:goldcoast@slrconsulting.com)

### PERTH

Level 1, 500 Hay Street  
Subiaco WA 6008  
Australia  
T: +61 8 9422 5900  
E: [perth@slrconsulting.com](mailto:perth@slrconsulting.com)

### WOLLONGONG

Level 1, The Central Building  
UoW Innovation Campus  
North Wollongong NSW 2500  
Australia  
T: +61 2 4249 1000  
E: [wollongong@slrconsulting.com](mailto:wollongong@slrconsulting.com)

### NELSON

6/A Cambridge Street  
Richmond, Nelson 7020  
New Zealand  
T: +64 274 898 628  
E: [nelson@slrconsulting.com](mailto:nelson@slrconsulting.com)

### CAIRNS

Level 1, Suite 1.06  
14 Spence Street  
Cairns QLD 4870  
Australia  
T: +61 7 4722 8090  
E: [cairns@slrconsulting.com](mailto:cairns@slrconsulting.com)

### MACKAY

1/25 River Street  
Mackay QLD 4740  
Australia  
T: +61 7 3181 3300  
E: [mackay@slrconsulting.com](mailto:mackay@slrconsulting.com)

### SUNSHINE COAST

Suite 2, 14-20 Aerodrome Rd  
Maroochydore QLD 4558  
Australia  
T: +61 7 3858 4800  
E: [SunshineCoast@slrconsulting.com](mailto:SunshineCoast@slrconsulting.com)

### WELLINGTON

12A Waterloo Quay  
Wellington 6011  
New Zealand  
T: +64 2181 7186  
E: [wellington@slrconsulting.com](mailto:wellington@slrconsulting.com)

### CANBERRA

GPO 410  
Canberra ACT 2600  
Australia  
T: +61 2 6287 0800  
E: [canberra@slrconsulting.com](mailto:canberra@slrconsulting.com)

### MELBOURNE

Level 11, 176 Wellington Parade  
East Melbourne VIC 3002  
Australia  
T: +61 3 9249 9400  
E: [melbourne@slrconsulting.com](mailto:melbourne@slrconsulting.com)

### SYDNEY

Tenancy 202 Submarine School  
Sub Base Platypus  
120 High Street  
North Sydney NSW 2060  
Australia  
T: +61 2 9427 8100  
E: [sydney@slrconsulting.com](mailto:sydney@slrconsulting.com)